

Chapter 26

Water

Part 1

Water Conservation Performance Standards for Plumbing Fixtures and Fittings

- §26-101. General Policy
- §26-102. Water Conservation Performance Standards for Plumbing Fixtures and Fittings
- §26-103. Special Provisions
- §26-104. Official Review and Modification
- §26-105. Penalties

Part 1**Water Conservation Performance Standards
for Plumbing Fixtures and Fittings****§26-101. General Policy.**

No water shall be provided for internal or external use to any residential, commercial, industrial, agricultural, recreational, governmental, or public building or structure of any kind which is constructed or remodeled and in which plumbing, water piping or water fixtures are to be installed, extended or altered in any way, and for which construction a permit is required to be obtained from Borough of Glendon (or would be required but for an exemption from a permit requirement for public or governmental agencies) unless the new, extended or altered plumbing, water piping and other water using fixtures therein conform to the requirements and standards of §26-102 of this Part. The provisions of this Part shall apply to any such building or structure for which such a building permit is issued, or would otherwise be required to be issued but for such an exemption, on or after date of adoption hereof.

(Ord. 92-4, 5/6/1992, §1)

§26-102. Water Conservation Performance Standards for Plumbing Fixtures and Fittings.

1. *Water Closets and Associated Flushing Mechanisms.* The water consumption of water closets shall not exceed an average of 1.6 gallons per flush cycle over a range of test pressures from 20 to 80 psi. The fixture shall perform in accordance with the test requirements of the ANSI A112.19.2M and ANSI A112.19.6M.

2. *Urinals and Associated Flushing Mechanisms.* Urinal water consumption shall not exceed an average of 1.5 gallons per flush cycle over a range of test pressures from 20 to 80 psi. The fixtures shall perform in accordance with the test requirements of ANSI A112.19.2M and ANSI A112.19.6M.

3. *Showerheads.* Showerhead discharge rates shall not exceed 3.0 gallons of water per minute over a range of test pressures from 20 to 80 psi. The fixture shall perform in accordance with the test requirements of ANSI A112.18.1M.

4. *Faucets.* Sink and lavatory faucet discharge rates shall not exceed 3.0 gallons of water per minute over a range of test pressures from 20 to 80 psi. The fixture shall perform in accordance with the test requirements of ANSI A112.18.1M.

(Ord. 92-4, 5/6/1992, §2)

§26-103. Special Provisions.

1. *Special Purpose Equipment.* The performance standards of §26-102 shall not apply to fixtures and fittings such as emergency showers, aspirator faucets, and blowout fixtures that, in order to perform a specialized function, cannot meet the specified standards.

2. *Exemptions.* Any person(s) may apply to the Borough of Glendon for an exemption to the terms of this Part, which may be granted by Council upon proof that some other device, system or procedure will save as much or more water as those set

forth herein, or that those set forth herein cannot be complied with, without undue hardship.

(*Ord. 92-4, 5/6/1992, §3*)

§26-104. Official Review and Modification.

The Council may, from time to time, modify, add to, or remove from the standards and restrictions herein.

(*Ord. 92-4, 5/6/1992, §4*)

§26-105. Penalties.

Any person, firm or corporation who shall violate any provision of the Part, upon conviction thereof, shall be sentenced to a fine of not less than \$100 nor more than \$1,000 plus costs and, in default of payment of said fine and costs, to a term of imprisonment not to exceed 30 days. Each day that a violation of this Part continues or each Section of this Part which shall be found to have been violated shall constitute a separate offense.

(*Ord. 92-4, 5/6/1992, §5; as amended by Ord. 2006-1, 12/6/2006*)